



Environmental Health Division

414 E. Main Street, Durham, NC 27701
Main: 919-560-7800 Fax: 919-560-7830

April 21, 2011

Mr. Nathan McHenry
Engineering Services
101 City Hall Plaza
Durham, North Carolina 27701

Dear Mr. McHenry:

I have identified through field investigations failing septic tank system at: 5020 Mimosa Drive, Parcel# 146966, Pin # 0729-01-46-4988, Owner Jenkins Affordable Housing, LLC. The system poses a public health risk by discharging untreated effluent to the ground surface. Therefore, it is the recommendation of this department that municipal sewer be extended to the above address.

Thank you for any assistance that you may be able to provide in dealing with this matter.

If you have any questions regarding this matter please do not hesitate to contact us at (919) 560-7800.

Sincerely,

Matthew Yearout, R.E.H.S.
Environmental Health Specialist
On-Site Water Protection

“To Preserve, Protect and Enhance the General Health and Environment of the Community”