



Public Health

100 Years of Service \* 1913-2013

ENVIRONMENTAL HEALTH DIVISION

BACTERIOLOGICAL WATER SAMPLE ANALYSIS REPORT

NAME ANGEL & MAVELIN ORELLANA

MAILING ADDRESS 602 PLEASANT DR. DURHAM NC

EMAIL ADDRESS mavelin~~orellana~~<sup>orellana</sup>@gmail.com 27703

LOCATION Same ZIP: 27703

TELEPHONE NUMBER 919-201-0464

NEW WELL  EXISTING WELL

SAMPLE TAKEN FROM: HOUSE TAP  WELL HEAD  OTHER

WELL LOCATION: ABOVE GRADE  BELOW GRADE

COMMENTS \_\_\_\_\_

COLLECTED BY NANCY WOOD KEHS

DATE/TIME 6/24/2014 11:15 AM

DELIVERED TO LAB @ 6/24/2014 12:30 PM

BACTERIAL COLIFORM TEST BY COLILERT METHOD

RESULTS: TOTAL BACTERIA: Negative  Positive

E. COLI: Negative  Positive

SAMPLE REPORTED BY: S. Alston/gw DATE: 6/25/14

Durham County Health Department does not recommend using water for human consumption from any well containing bacteria.

"Bacteria not found" (a negative result) does not guarantee either a properly constructed well or safe water



Public Health

## ENVIRONMENTAL HEALTH DIVISION

July 8, 2014

Owner: Springleaf Financial Services of NC  
303 E Franklin Blvd Ste 5  
Gastonia, NC 28053

Property: 602 Pleasant Dr  
Durham, NC 27703

CC: Angel and Mavelin Orellana

RE: Private Water Well

On 4/28/2014 the well serving 602 Pleasant Dr tested positive for total bacteria, a follow up sampling on 6/24/2014 tested positive for E.coli. It is not recommended that you drink the water until the well has been repaired and test negative for total bacteria and E. coli. If municipal water is available, it is recommended that you connect to municipal services and cease use of the well. If the well is discontinued, please have a licensed well contractor properly abandon the well.

Sincerely,

Matthew Yearout, REHS  
Monitoring Program Specialist  
On-Site Water Protection