

SPILLS AND OVERFLOWS FROM JULY 2013 THROUGH JUNE 2014

LOCATION	DATE	VOLUME Gallons discharge	VOLUME Gallons to creek	CAUSE	REMEDY
Eno River at Roxboro Road	7/4/2013	3,600	3,600	Severe Natural Condition/Inflow and Infiltration	Cleaned and Tved Main Line, Inspected for I/I issues
1700 Logan Street	7/24/2013	650	650	Debris in Line	Cleaned and Tved Main Line
#12 Knob Court	11/7/2013	240	240	Grease/Debris in Line	Cleaned and Tved Main Line
5722 Wanderlust Lane	12/21/2013	3,000	2,500	Pipe Failure	Cleaned and Tved Main Line, Replaced 80 ft of 12' DIP at 4 locations
Cheek Road and Hwy 70	1/13/2014	288,000	288,000	Grease/Debris in Line	Cleaned and Tved Main Line
905 Elmira Ave.	1/15/2014	14,400	13,000	Vandalism/ Debris in Line	Cleaned and Tved Main Line
117 Radcliff Circle	1/20/2014	360	360	Grease / Roots	Cleaned / Sawed Roots / Tved Main Line
1615 Valley Run	1/20/2014	900	900	Grease / Roots	Cleaned / Sawed Roots / Tved Main Line
I-85 and Guess Road Intersection	1/27/2014	240	240	Grease	Cleaned and Tved Main Line
Midland Terrace / I-85	2/14/2014	2,100	2,100	Debris in Line	Cleaned and Tved Main Line
Waterford Valley Drive	3/9/2014	1,920	1,920	Grease	Cleaned and Tved Main Line
3814 Valleydale Drive	3/13/2014	225	0	Other	Cleaned and Tved Main Line
1700 Ward Street	3/14/2014	600	600	Grease / Roots	Cleaned / Sawed Roots / Tved Main Line
3130 NC HWY 751, Turnage Heights Pump Station	3/20/2014	5,375	4,125	Other	Repaired Pumps off line at the station
2105 E. NC HWY 54 (Parking Lot)	4/2/2014	900	900	Grease	Cleaned and Tved Main Line
518 Bacon Street	5/15/2014	1,800	1,800	Severe Natural Condition	Cleaned and Tved Main Line, Inspected for I/I issues

I/I = Inflow/infiltration

Total Number of Spills = 16
Total 324,310 gallons

