


**SPILLS AND OVERFLOWS FROM JULY 2011 THROUGH JUNE 2012**

LOCATION	DATE	VOLUME Gallons discharge	VOLUME Gallons to creek	CAUSE	REMEDY
1433 Clermont Road	07/11/11	4,320	4,320	Unknown blockage	Cleaned and TV'd main line
2200 Stroller Avenue	07/15/11	900	900	Pipe failure/roots	Repaired 8" sewer main with full seal clamp & Cleaned/Sawed Roots/TV'd
4012 Bristlewood Drive	07/19/11	12,960	12,960	Blockage of roots	Cleaned/Sawed Roots/TV'd main line
1516 Blount Street	07/24/11	60	60	Blockage of roots	Cleaned/Sawed Roots/TV'd main line
1502 Granby Street	07/29/11	2,880	2,880	Blockage of roots	Cleaned/Sawed Roots/TV'd main line
Forge Road Outfall #1	08/15/11	10,080	10,080	Blockage of grease	Cleaned and TV'd main line
1800 Palmer Street	08/16/11	14,256	720	Blockage of roots	Cleaned/Sawed Roots/TV'd
South Alston Avenue & Hwy 55	08/22/11	25	25	Blockage of roots/rags	Cleaned/Sawed Roots/TV'd main line
925 Harvest Street	09/09/11	45	45	Blockage of debris	Cleaned and TV'd main line
1406 W. Markham Avenue	09/12/11	120	120	Pipe failure	Outside drop connection
906 W. Trinity Avenue	09/16/11	75	75	Blockage of roots	Cleaned/Sawed Roots/TV'd main line
912 Lorraine Drive	09/18/11	750	750	Blockage of debris	Cleaned and TV'd main line
3505 Medford Road	10/13/11	600	600	Blockage of grease/roots	Cleaned/Sawed Roots/TV'd main line
212 Selkirk Place	10/13/11	600	600	Blockage of debris	Cleaned and TV'd main line
219 S. Mangum Street	10/24/11	810	810	Blockage of debris	Cleaned and TV'd main line
Cambridge Drive & Devon Road	11/09/11	50	50	Blockage of roots	Cleaned/Sawed Roots/TV'd main line
2806 Duke Homestead Road	11/11/11	100	100	Blockage of roots	Cleaned/Sawed Roots/TV'd main line
1425 Sedgefield Street	11/15/11	100	100	Pipe failure	Point repair on sewer main
Hardee Street & Naples Place	11/17/11	900	900	Blockage of roots/rags	Cleaned/Sawed Roots/TV'd main line
Slateworth Drive	11/21/11	90	90	Blockage of grease	Cleaned and TV'd main line
Midland Terrace & I-85	11/22/11	3,000	3,000	Blockage of grease	Cleaned and TV'd main line

1506 Lakeland Street	11/28/11	14,400	14,400	Blockage of roots	Cleaned/Sawed Roots/TV'd main line
Parkridge Road (Woodcroft Pool)	12/05/11	2,880	2,880	Blockage of grease	Cleaned and TV'd main line
1203 Wall Street	01/07/12	8,640	8,640	Blockage of roots	Cleaned/Sawed Roots/TV'd main line
Flowers Dr (Duke Hospital South)	01/10/12	45	45	Blockage of roots	Cleaned/Sawed Roots/TV'd main line
2500 Indian Trail	01/25/12	25	25	Blockage of roots/rags	Cleaned/Sawed Roots/TV'd main line
Dayton Avenue Outfall	02/06/12	400	400	Pipe failure	Point repair on sewer main
12 Montcrest Drive	02/16/12	500	500	Blockage of grease/rags	Cleaned and TV'd main line
Northeast Creek Parkway	02/21/12	300	300	Sewer plug left in main by contractor	Removed sewer plug, cleaned and TV'd main line
Highgate Drive Outfall	03/06/12	440	440	Blockage of roots	Cleaned/Sawed Roots/TV'd main line
4023 Wake Forest Hwy	03/13/12	720	200	Blockage of debris	Cleaned and TV'd main line
Main Street & Duke Street	03/14/12	150	150	Pipe failure	Point repair on sewer main
1309 Hudson Avenue	03/20/12	12,960	12,000	Blockage of grease/rags	Cleaned and TV'd main line
Stage Road Pump Station	03/24/12	750	750	I/I from heavy rain event	SSO stopped when pumps caught up
11 Yarmouth Place	04/03/12	7,200	7,200	Blockage of roots	Cleaned/Sawed Roots/TV'd main line
2526 Atlantic Street	04/04/12	600	600	Blockage of grease	Cleaned and TV'd main line
602 Orindo Drive	04/10/12	120	120	Unknown blockage	Cleaned and TV'd main line
5925 Farrington Road	04/12/12	300	300	Blockage of grease	Cleaned and TV'd main line
917 Liberty Street	05/21/12	300	250	Blockage of grease/roots	Cleaned/Sawed Roots/TV'd main line
5216 Penrith Drive	05/31/12	60	40	Blockage of grease	Cleaned and TV'd main line
Case Street & Pettigrew	06/23/12	840	840	Blockage of debris	Cleaned and TV'd main line
8 Mercury Court	06/27/12	360	360	Blockage of roots	Cleaned/Sawed Roots/TV'd main line
Bedford Street & Nations Avenue	06/30/12	480	480	Vandalism	Removed Sticks, Cleaned and TV'd main line
Total Number of Spills = 43		Total Volume = 105,191 Gallons			

### Number of Spills



### Total Gallons Spilled

