

## **SPILLS AND OVERFLOWS FROM JULY 2008 THROUGH JUNE 2009 (Modified)**

<b>LOCATION</b>	<b>DATE</b>	<b>VOLUME Gallons discharge</b>	<b>VOLUME Gallons to creek</b>	<b>CAUSE</b>	<b>REMEDY</b>
100 Plantation Drive	07/08/08	500	500	Pipe Failure	Repaired force main with 4" PVC coupling
4 Stoneridge Circle	07/08/08	1,800	1,800	Blockage of grease/roots	Cleaned/Sawed Roots/Tved main line
2724 Marlin Drive	07/26/08	14,400	14,400	Blockage of grease/roots	Cleaned/Sawed Roots/Tved main line
1512 Lakeland Street	07/29/08	500	250	Blockage of roots	Cleaned/Sawed Roots/Tved main line
2411 Prince Street	08/16/08	30,240	30,240	Blockage of grease/rags	Cleaned and Tved main line
Newcastle Outfall	08/23/08	5,000	5,000	Blockage of debris	Removed insert, cleaned and Tved main line
Pennock Road & Broach Road	09/03/08	12,960	12,960	Blockage of rags	Cleaned and Tved main line
3000 Sparger Road Pump Station	09/06/08	300	300	Severe natural condition	Reset manhole frame & cover, raised manholes
Rivermont Pump Station	09/06/08	800	800	Pump Station equipment failure	10 second delay was inserted between the two pumps
Dearborn Drive & Martin Street	09/13/08	720	720	Blockage of grease	Cleaned and Tved main line
3014 Dixon Road	09/29/08	270	270	Blockage of grease/rags	Cleaned and Tved main line
Cole Mill Road & Clarion Drive	09/30/08	8,600	8,600	Blockage of rags	Cleaned and Tved main line
3106 Ithaca Street	10/06/08	900	800	Blockage of roots	Cleaned/Sawed Roots/Tved main line
Horton Road & Guess Road	10/06/08	54,000	40,000	Blockage of debris	Cleaned and Tved main line
2721 Thelma Street	10/13/08	14,400	14,400	Blockage of grease/roots	Cleaned and Tved main line
2721 Thelma Street	10/15/08	900	900	Pipe failure	Cleaned and Tved main line - Replaced 10' of line
404 S.Adams Street	10/26/08	2,500	2,500	Blockage of grease/rags	Cleaned and Tved main line
1100 MLK Jr. Parkway	11/13/08	21,600	21,600	Blockage of grease/rags	Cleaned and Tved main line
Grant Street & Umstead Street	11/18/08	500	500	Grease blockage	Cleaned and Tved main line
Brentwood Road & Euclid Road	11/19/08	14,400	14,400	Blockage of grease/roots	Cleaned/Sawed Roots/Tved main line
5301 Lacy Road	11/24/08	28,800	28,800	Blockage of grease/rags	Cleaned and Tved main line
2045 Crystal Lake Road	12/20/08	12,000	9,600	Blockage of debris	Removed insert, cleaned and Tved main line
Cornwallis Road & Hwy 55	12/22/08	26,250	20,000	Blockage of grease/debris	Cleaned and Tved main line
912 Wadesboro Street	12/26/08	13,000	200	Blockage of grease/rags	Cleaned and Tved main line
509 Usher Street	12/30/08	14,000	14,000	Blockage of grease/rags	Cleaned and Tved main line
Midland Terrace east of I-85	01/05/09	20,000	13,000	Blockage of grease/rags	Cleaned and Tved main line
5619 McCormick Road	01/14/09	2,800	2,000	Blockage of debris	Cleaned and Tved main line
1118 Burch Avenue	01/29/09	10,000	10,000	Blockage of roots	Cleaned/Sawed Roots/Tved main line
3408 Glasson Street	02/01/09	4,200	4,200	Grease blockage	Cleaned and Tved main line
900 Windermere Drive	02/09/09	7,200	7,200	Pipe failure	Cleaned and Tved main line - Replaced 10' of line

## **SPILLS AND OVERFLOWS FROM JULY 2008 THROUGH JUNE 2009(Modified)**

<b>LOCATION</b>	<b>DATE</b>	<b>VOLUME Gallons discharge</b>	<b>VOLUME Gallons to creek</b>	<b>CAUSE</b>	<b>REMEDY</b>
33 Jenee Lane	02/16/09	1,000	500	Grease blockage	Cleaned and Tved main line
1007 Taylor Street	03/01/09	900	900	Blockage of grease/rags	Cleaned and Tved main line
Angier Avenue & King Street	03/03/09	500	500	Grease blockage	Cleaned and Tved main line
435 Chandler Road	03/07/09	14,000	14,000	Blockage of grease/debris	Removed sticks, cleaned and Tved main line
Eno River State Park–Roxboro Rd	03/12/09	500	0	Severe natural condition	Cleaned and Tved main line
1912 Essex Road	03/15/09	5,000	5,000	Severe natural condition	Cleaned and Tved main line
Liberty Street & Eastway Avenue	03/27/09	900	900	Grease blockage	Cleaned and Tved main line
1702 Woodburn Avenue	04/07/09	6,000	6,000	Blockage of roots	Cleaned/Sawed Roots/Tved main line
2315 Sprunt Avenue	04/13/09	1,440	1,440	Blockage of roots	Cleaned/Sawed Roots/Tved main line
3511 Emily Street	04/14/09	6,000	6,000	Vandalism	Cleaned and Tved main line, bolted frame, installed cover
2506 Winburn Avenue	04/17/09	43,000	43,000	Grease blockage	Cleaned and Tved main line
Wintergreen Place & Crowell St	04/24/09	14,400	14,400	Blockage of grease/rags	Cleaned and Tved main line
Mathison Street & Potter Street	05/11/09	12,000	12,000	Blockage of grease	Cleaned and Tved main line
Main Street south of Miami Blvd	05/12/09	1,500	1,500	Vandalism	Cleaned and Tved main line
4707 Rollingwood Drive	05/13/09	1,200	1,200	Blockage of grease/roots	Cleaned/Sawed Roots/Tved main line
1908 Cornwallis Road	05/15/09	40,000	40,000	Blockage of debris	Removed insert, cleaned and Tved main line
3420 Wake Forest Hwy	05/19/09	10,000	10,000	Blockage of debris	Cleaned and Tved main line
1409 Clarendon Street	06/02/09	6,000	6,000	Blockage of grease/rags	Cleaned and Tved main line
619 Stallings Road	06/20/09	700	700	Grease blockage	Cleaned and Tved main line
705 Obsidian Way	06/25/09	2,880	2,880	Grease blockage	Cleaned and Tved main line
Liggett St & Corporation St	06/26/09	2,000	2,000	Blockage of debris	Cleaned and Tved main line
Blair Street & Ader Street	06/29/09	300	0	Blockage of grease/roots	Cleaned/Sawed Roots/Tved main line
708 Forge Road	06/29/09	43,000	43,000	Blockage of grease/rags	Cleaned and Tved main line
Total Number of Spills = 55		Total Volume = 537,460 gallons			