

SPILLS AND OVERFLOWS FROM JULY 2009 THROUGH JUNE 2010

LOCATION	DATE	VOLUME Gallons discharge	VOLUME Gallons to creek	CAUSE	REMEDY
318 Wayne Circle	07/11/09	800	800	Blockage of debris	Cleaned and Tved main line
5337 N.Roxboro Road	07/18/09	900	900	Blockage of roots	Cleaned/Sawed Roots/Tved main
Holloway Street & Hubert	07/20/09	360	360	Blockage of grease	Cleaned and Tved main line
4727 University Drive	07/25/09	10,000	10,000	Blockage of	Cleaned and Tved main line
E.Forest Hills Blvd & Beverly	08/17/09	300	300	Pipe failure	Cleaned and Tved main line -
3522 Ridge Road	08/28/09	3,000	3,000	Blockage of grease	Cleaned and Tved main line
800 Clayton Road	09/09/09	14,400	14,400	Blockage of	Cleaned and Tved main line
E.Forest Hills Blvd & Beverly	09/18/09	150	150	Pipe failure	Cleaned and Tved main line -
Oregon Street & Campus	09/23/09	240	240	Blockage of roots	Cleaned/Sawed Roots/Tved main
3810Danube Lane	10/02/09	200	100	Blockage of roots	Cleaned/Sawed Roots/Tved main
1107 Fidelity Drive	10/05/09	21,600	21,600	Blockage of grease	Cleaned and Tved main line
1534 Cher Drive	10/06/09	50,000	50,000	Blockage of grease	Cleaned and Tved main line
2230 Hwy 54	10/09/09	6,000	6,000	Blockage of grease	Cleaned and Tved main line
Berkeley St & Markham Ave	10/10/09	3,000	3,000	Blockage of	Cleaned/Sawed Roots/Tved main
Jackson Street & Gordon	10/20/09	800	800	Contractor Damage	Cleaned and Tved main line, reset
708 E.Club Blvd	10/26/09	500	500	Pipe failure	Cleaned and Tved main line – Installed 2” patch kit
1735 Athens Drive	10/29/09	100	100	Pipe failure	Cleaned and Tved service line -
111 Rock Cottage Court	10/29/09	100	100	Pipe failure	Cleaned and Tved main line -
910 W.Trinity Avenue	11/11/09	1,200	1,200	Severe natural	Cleaned and Tved main line,
Cranford Road & Perkins	11/11/09	1,800	1,800	Severe natural	Cleaned and Tved main line,
1912 Essex Road	11/11/09	1,800	1,800	Severe natural	Cleaned and Tved main line,
Lavender Street & Acadia	11/12/09	800	800	Severe natural	Cleaned and Tved main line,
4711 Hope Valley Road	11/25/09	50	0	Blockage of grease	Cleaned and Tved main line
Turnkey Pump Station	12/02/09	800	800	Severe natural	Checked pumps at station
505 Hanson Road	12/15/09	100	100	Blockage of debris	Removed insert, cleaned and
602 Chandler Road	12/30/09	1,800	1,800	Blockage of	Cleaned and Tved main line
Sima Street & Plum Street	01/04/10	3,600	3,600	Vandalism	Cleaned and Tved main line
4400 Thetford Road	01/07/10	7,200	7,200	Blockage of debris	Cleaned and Tved main line
Morreene Road & Erwin	01/08/10	43,000	43,000	Blockage of grease	Cleaned and Tved main line
6201 Pine Glen	01/12/10	6,000	6,000	Blockage of	Cleaned and Tved main line
Constitution Drive & NC 751	01/18/10	5,400	5,400	Blockage of	Removed insert/Cleaned/Sawed
Constitution Drive & NC 751	02/01/10	2,400	2,400	Blockage of	Cleaned/Sawed Roots/Tved main
1806 Cannon Drive	02/08/10	21,600	21,600	Blockage of	Cleaned and Tved main line
2808 Croasdaile Drive	03/01/10	720	720	Blockage of grease	Cleaned and Tved main line
2624 Ross Road	03/07/10	960	960	Blockage of grease	Cleaned and Tved main line
Morgan Street & Duke Street	03/09/10	20,000	20,000	Blockage of	Cleaned/Sawed Roots/Tved main
Cumberland Drive Outfall	03/09/10	1,540	540	Blockage of grease	Cleaned and Tved main line
7015 Falconbridge Road	03/16/10	1,800	1,800	Blockage of debris	Cleaned and Tved main line
Maplewood Cemetery Outfall	03/19/10	28,800	28,800	Blockage of	Cleaned and Tved main line

