

SPILLS AND OVERFLOWS FROM JULY 2010 THROUGH JUNE 2011

LOCATION	DATE	VOLUME Gallons discharge	VOLUME Gallons to creek	CAUSE	REMEDY
1510 Robinhood Road	07/02/10	1500	1500	Blockage of	Cleaned/Sawed Roots/Tved main
Midland Terrace & I-85	07/06/10	14,400	11,000	Blockage of	Cleaned and Tved main line
1704 Liberty Street	07/25/10	250	250	Blockage of grease	Cleaned and Tved main line
12 Deep Forest Drive	08/04/10	8,000	8,000	Blockage of debris	Removed insert, cleaned and
707 Fargo Street	08/04/10	700	700	Blockage of	Cleaned/Sawed Roots/Tved main
108 Muldee Street	08/30/10	14,400	14,400	Vandalism (large	Cleaned and Tved main line
1430 Sima Street	09/10/10	5,100	5,100	Blockage of grease	Cleaned and Tved main line
200 Woodcroft Parkway	09/11/10	600	600	Blockage of grease	Cleaned and Tved main line
1605 Farmington Drive	09/30/10	2,880	0	Blockage of debris	Removed MH step, cleaned and
1820 Stage Road Lift Station	10/06/10	300	50	Pump Station	Reset circuit breaker and rewired
1203 Woodcroft Parkway	10/12/10	2,400	2,400	Blockage of	Cleaned and Tved main line
308 N.Guthrie Avenue	10/22/10	11,520	11,520	Pipe failure	Replaced section of VCP with DIP
4709 Highgate Drive	10/26/10	1,200	1,200	Blockage of debris	Cleaned and Tved main line
2915 Independence Avenue	10/28/10	14,400	14,400	Blockage of	Cleaned and Tved main line
211 Dacian Avenue	11/08/10	10,080	10,080	Blockage of	Cleaned/Sawed Roots/Tved main
Ridgeway Avenue Outfall	12/06/10	750	250	Blockage of grease	Cleaned and Tved main line
4211 Swarthmore Road	12/12/10	1,440	500	Blockage of roots	Cleaned/Sawed Roots/Tved main
24 Phauff Court	12/27/10	8,640	8,640	Blockage of	Cleaned/Sawed Roots/Tved main
1534 Cher Drive	01/04/11	2,400	2,400	Blockage of	Cleaned and Tved main line
900 Windermere Drive	01/06/11	1,200	1,200	Blockage of debris	Cleaned and Tved main line
209 Eagle Campus Drive	01/10/11	3,000	2,250	Pipe failure	Cleaned and Tved main line –
313 Foster Street	01/14/11	1,800	1,800	Blockage of debris	Cleaned and Tved main line
1007 Taylor Street	01/15/11	7,200	1,700	Blockage of debris	Cleaned and Tved main line
25 Saint Andrews Court	01/20/11	6,300	6,300	Blockage of debris	Cleaned and Tved main line
1414 Woodland Drive	01/21/11	50,400	50,400	Blockage of	Cleaned/Sawed Roots/Tved main
574 Liberty Street	01/31/11	540	540	Pipe failure	Cleaned and Tved main line -
1613 James Street	01/31/11	720	720	Blockage of roots	Cleaned/Sawed Roots/Tved main
4101 N.Roxboro Road	02/06/11	720	360	Blockage of grease	Cleaned and Tved main line
8 Summer Ridge Court	02/07/11	300	300	Vandalism (rock/tree	Cleaned and Tved main line
900 Holloway Street	02/09/11	180	180	Blockage of	Cleaned and Tved main line
2715 Leyburn Place	02/10/11	1,440	1,440	Blockage of roots	Cleaned/Sawed Roots/Tved main
12 Bentwood Place	02/10/11	7,200	7,200	Blockage of	Cleaned/Sawed Roots/Tved main
Duke Street & Main Street	02/11/11	11,520	11,520	Blockage of grease	Cleaned and Tved main line
3914 Linden Terrace	02/13/11	960	960	Blockage of grease	Cleaned and Tved main line
3200 Victor Avenue	02/16/11	1,440	1,440	Blockage of grease	Cleaned and Tved main line
3814 Valleydale Drive	02/18/11	360	360	Blockage of grease	Cleaned and Tved main line
Briggs Ave & Lawson St	02/23/11	2,880	2,880	Blockage of debris	Cleaned and Tved main line
Bertrand Avenue MH# 29126	02/23/11	180	180	Blockage of debris	Cleaned and Tved main line
1403 Valley Run	02/27/11	600	600	Blockage of grease	Cleaned and Tved main line
Nixon Street Outfall	03/04/11	360	360	Blockage of grease	Cleaned and Tved main line

Stadium Drive Outfall	03/13/11	20,160	20,160	Blockage of debris	Cleaned and Tved main line
3503 Portico Lane	03/22/11	100	100	Pipe failure	Repaired 4" sewer service with
1714 Faison Road	03/24/11	240	120	Blockage of debris	Cleaned and Tved main line
Hwy 751 & Cranford Road	03/30/11	900	900	Severe natural	Cleaned and Tved main line,
2523 Holloway Street	04/01/11	360	360	Blockage of debris	Cleaned and Tved main line
1701 Cornwallis Road	04/17/11	7,200	1,200	Blockage of grease	Cleaned and Tved main line
Liberty Street & Peachtree	04/19/11	360	360	Blockage of debris	Cleaned and Tved main line
Erwin Road & Downing Street	04/19/11	600	600	Blockage of debris	Cleaned and Tved main line
S.Roxboro Street & Juliette	05/03/11	20,160	20,160	Blockage of grease	Cleaned and Tved main line
820 Clayton Road	05/03/11	14,400	14,400	Blockage of debris	Cleaned and Tved main line
3801 Meriwether Drive	05/19/11	4,320	4,320	Blockage of grease	Cleaned and Tved main line
E.Forest Hills Blvd Outfall	05/31/11	14,400	7,000	Blockage of roots	Cleaned/Sawed Roots/Tved main
Hwy 70 & Cheek Road	06/02/11	14,400	10,000	Blockage of roots	Cleaned/Sawed Roots/Tved main
809 E.Oak Drive	06/23/11	2,520	2,000	Blockage of grease	Cleaned and Tved main line
Total Number of Spills = 54		Total Volume = 300,380 Gallons			

