

DOCUMENT 00 91 13

ADDENDA

ADDENDUM NUMBER 1

DATE: September 23, 2016

PROJECT: Third Fork Creek Stream Restoration

CONTRACT NUMBER: SD-2016-03

OWNER: The City of Durham

ENGINEER: Wildlands Engineering, Inc.

TO: Prospective Bidders

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated August 29, 2016, with amendments and additions noted below.

Acknowledge receipt of this Addendum in the space provided in the Bid form. Failure to do so may disqualify the Bidder.

This Addendum consists of 2 pages.

REQUESTS FOR INFORMATION

1. For the Rock Outlet Protection of Vernal Pools in Area 2 and Overflow Channel in Area 3, could a detail with dimensions (length and width) and/or an anticipated area along with the depth of stone be provided?
 - a. The Rock Outlet Protection for the Vernal Pools should be constructed with a top width of approximately 5-feet and 1-foot deep with 2:1 side slopes, and filled with 6-inches of stone. The length will vary depending on the distance from the vernal pool outlet to the newly constructed stream channel.
 - b. The Rock Outlet Protection for the Overflow Channel should be consistent with the dimensions of the Overflow Channel. A small detail is provided on sheet 2.14. The top width is approximately 35-feet wide (defined 30-foot bottom width) and 1 to 2-feet deep depending on the exact depth to tie to existing grade. Overflow Channel and Rock Outlet Protection side slopes should be 3:1. The length of the Rock Outlet Protection should be about 4 to 5-feet and filled with 6-inches of stone.

2. How will the contractor be compensated for the pavement repair required in Area 2? Should it be incidental to an item or should an item be added for this work?
 - a. The pavement repair in Area 2 shall be considered incidental to item no. 2, "Mobilization and Demobilization." There is not a separate pay item for the pavement repair. The repair is approximately 50-feet in length.

DOCUMENT 00 01 10 - TABLE OF CONTENTS

3. Add the following document under CONTRACTING REQUIREMENTS, "00 91 13 Addendum No. 1."

DOCUMENT 00 11 16 – INVITATION TO BID

4. The City of Durham will open sealed formal Bids submitted by Bidders at 1:30 pm, Thursday, October 6, 2016 for Contract SD-2016-03, Project: Third Fork Creek Stream Restoration in the Public Works Department Conference Room, Third Floor, 101 City Hall Plaza, Durham NC.

END OF DOCUMENT