

Addendum # 5
ST-264 Fayetteville Road Improvements
City of Durham
September 13, 2018

The following changes and clarifications are applicable to the referenced project and are now a part of its contract documents. Where any article, division, or subparagraph of the original contract documents or other addenda is supplemented herein, the provisions of the original documents shall remain in effect. All the supplemental provisions shall be considered as added thereto. Where any such article, division, or subparagraphs are amended, voided, or superseded thereby, the provisions of such article, division, or subparagraph not so specifically amended, voided, or superseded shall remain in effect.

The attention of each contractor is called to the following clarifications, additions to, and changes in the plans and specifications, on the above project. It will be the responsibility of each contractor to call such clarifications, additions, and changes in plans and specifications to the attention of subcontractors concerned. The City in no way assumes any responsibility for notifying any subcontractor, material dealers, or others not having received the original contract documents.

Item 1: Acknowledgement of Addendum #4 and Addendum #5

Please send email to Charles.Rice@durhamnc.gov stating that you have received Addendum #4 and Addendum #5.

Item 2: Bidding Questions:

1. Any reason why there is an asterisk on the line item for DRILLED PIER FOUNDATION? **Asterisk does not refer to anything in the bid.**
2. Also, the Buxton-Riddle also has metal poles, but no foundations. **Line item #128 has 5 Metal Pole Foundations.**
3. When is the last day for questions? **September 12th at 3:00 pm.**
4. Please provide foundation specs for the 5 Metal Pole Foundations. **There is one set of signal specifications for both projects.**
5. The 12 Metal Poles in the Fayetteville Road section of this call for 67 Cubic Yards which equate to approximately 6.7 Cubic Yards per foundation. **The assumption is 5.5 CY per foundation, based on 42" diameter at approximately 15' deep.**
6. Is it safe to assume the 5 Metal Poles in the Buxton Riddle section of this will be the same (6.7 Cubic Yards per foundation)? **The pole foundations on Buxton Riddle are being bid as "each", so you will need to make an assumption in your bid as to the amount of concrete you may need to cover your cost.**
7. Do you know if the City has a listing for DBE trucking? **There is no listing for DBE trucking only. You will find those firms under HUB firms on the State's HUB website or on NCDOT's website. Either way the utilization of certified firms county both the same way.**