



NOTES:

1. PLACE SAW-CUT TRAVERSE CONTROL JOINTS AT MAXIMUM OF 10' O/C OR AS OTHERWISE SHOWN ON PLANS.
2. PLACE TRANSVERSE EXPANSION JOINTS AT MAXIMUM OF 30' O/C OR AS SHOWN ON PLANS .
3. TRAIL SECTION SHOWN MAY BE ALTERED TO CONFORM TO GEOTECHNICAL INVESTIGATION FINDINGS.
4. CONCRETE TO BE MIN. 3000 PSI @ 28 DAYS AIR ENTRAINED.
5. USE MIRAFI 500X GEOTEXTILE FABRIC OR EQUIVALENT.

 <p><b>CITY OF DURHAM</b></p>	<p>Durham Parks &amp; Recreation 400 Cleveland Street Durham, NC 27701</p>	<p><b>CITY OF DURHAM, NC</b> USE WITH THE STANDARD SPECIFICATIONS ONLY</p>	<p>Voice (919) 560-4355 <a href="http://www.durhamnc.gov">www.durhamnc.gov</a></p>		
	<p>CONCRETE SURFACED TRAIL DETAIL</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">SCALE: N.T.S.</td> <td style="width: 50%;">DETAIL#: TD-01.00</td> </tr> <tr> <td>REVISION DATE: 9/5/2019</td> <td>SHEET#: 1 of 1</td> </tr> </table>	SCALE: N.T.S.	DETAIL#: TD-01.00	REVISION DATE: 9/5/2019
SCALE: N.T.S.	DETAIL#: TD-01.00				
REVISION DATE: 9/5/2019	SHEET#: 1 of 1				