



NOTES:

1. PLACE SAW-CUT TRAVERSE CONTROL JOINTS AT MAXIMUM OF 10' O/C OR AS OTHERWISE SHOWN ON PLANS.
2. PLACE TRANSVERSE EXPANSION JOINTS AT MAXIMUM OF 30' O/C OR AS SHOWN ON PLANS .
3. TRAIL SECTION SHOWN MAY BE ALTERED TO CONFORM TO GEOTECHNICAL INVESTIGATION FINDINGS.
4. CONCRETE TO BE MIN. 3000 PSI @ 28 DAYS AIR ENTRAINED.
5. USE MIRAFI 500X GEOTEXTILE FABRIC OR EQUIVALENT.



Durham Parks & Recreation  
400 Cleveland Street  
Durham, NC 27701

**CITY OF DURHAM, NC**  
USE WITH THE STANDARD SPECIFICATIONS ONLY

Voice (919) 560-4355

www.durhamnc.gov

**CONCRETE SURFACED  
SIDE PATH DETAIL (WITH CURB)**

SCALE: N.T.S.	DETAIL# TD-01.10
REVISION DATE: 9/19/2019	SHEET# 1 of 1